



REACTION TO FIRE CLASSIFICATION REPORT IN ACCORDANCE WITH PN-EN 13501-1:2019

Contract no. 00698/20/Z00NZP

Sponsor:	Zakłady LENTEX Spółka Akcyjna ul. Powstańców Śląskich 54 42-700 Lubliniec
Prepared by:	Zakład Badań Ogniwych Instytutu Techniki Budowlanej ul. Filtrowa 1 00-611 Warszawa
Product name:	PVC floor covering with interchangeably used trade names SERENITY, OASIS, 260 030
Classification report no.:	00698/20/Z00NZP-ENG (English version of classification 00698/20/Z00NZP)
Issue number: 1	Copy no. 1
Date of issue:	2020.04.06

This classification report consists of three pages and may only be used or reproduced in its entirety.

1. Introduction

This classification report defines the classification assigned to PVC floor covering with interchangeably used trade names SERENITY, OASIS, 260 030 in accordance with the procedures given in PN-EN 13501-1:2019.

2. Details of classified product

2.1 General

The product is defined as PVC floor covering used in residential buildings and public buildings.

2.2 Product description

2.3 The product, is described below.

PVC floor covering with interchangeably used trade names SERENITY, OASIS, 260 030.
Total thickness of PVC floor covering: 2,60 mm.
Thickness of usable layer (external) of PVC floor covering: 0,30 mm.
Surface mass of PVC floor covering: 1850 g/m².

3. Test reports & test results in support of classification

3.1 Test reports

Name of laboratory	Name of sponsor	Test report no.	Test method
Fire Testing Laboratory of ITB	LENTEX Spółka Akcyjna	LZP02-00698/20/Z00NZP	PN-EN ISO 11925-2:2010
		LZP01-00698/20/Z00NZP	PN-EN ISO 9239-1:2010

3.2 Test results

Test method	Parameter	Number of tests	Results	
			Continuous parameter – mean (m)	Compliance with parameters
PN-EN ISO 11925-2:2010 Exposure 15 s	$F_s \leq 150$ mm	6	(-)	Y
PN-EN ISO 9239-1:2010	Critical heat flux (kW/m ²)	3	7,4	(-)
	Smoke production (% • min)		142,8	(-)
(-): do not concern Y: Yes N: No				

4 Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with PN-EN 13501-1:2019.

4.2 Classification

PVC floor covering with interchangeably used trade names SERENITY, OASIS, 260 030, in relation to its reaction to fire behaviour are classified:

C_{fl}

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

Fire behaviour		Smoke production	
C_{fl}	-	s	1

i.e.: **C_{fl}-s1**

Reaction to fire classification: C_{fl}-s1

4.3 Field of application

This classification is valid for the following product parameters:

- Product described in point 2 this classification report
- Product can be used with substrates with reaction to fire classification A1 or A2 with or without dispersion adhesive.

5 Limitation

The classification given above remains valid as long as:

- test method remains unchanged,
- product standard or technical approval remains unchanged,
- constructional or material modifications do not exceed limits of the field of application defined in 4.3.

This classification report has been issued in three copies (2 for client, 1 for Fire Research Department of ITB). Additional signed copies can be issued by Fire Research Department of ITB on the request of the report's owner only.

"The classification assigned to the product in this report is appropriate to a declaration of performance (till 1st July of 2013 – declaration of conformity) by the manufacturer within the context of system 3 of assessment and verification of constancy of performance (till 1st July 2013 – system of conformity) and CE marking according to harmonized technical specification of the product and with Regulation (EU) no. 305/2011 of The European Parliament and of The Council of 9 March 2011 laying down harmonized conditions for the marketing construction products and repealing Council Directive 89/106/EEC.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system of assessment and verification of constancy of performance 3 is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested."

This classification document does not represent type approval or certification of the product.

SIGNED



Mariusz Żońnik

APPROVED

HEAD
of Fire Research Department

Bartłomiej Papis, PhD Eng.

